

SACRAMENTO AREA SEWER DISTRICT NOTES

REVISED 12/21/2022

1. ALL CONSTRUCTION AND MATERIALS USED WITHIN THE PIPE ZONE MUST BE IN ACCORDANCE WITH THE MOST RECENT EDITION OF THE SACRAMENTO AREA SEWER DISTRICT (SACSEWER) STANDARDS AND SPECIFICATIONS (STANDARDS). THE LATEST STANDARDS EDITION AT THE TIME OF PLAN APPROVAL WILL TAKE PRECEDENCE. THE CONTRACTOR MUST USE ALL APPLICABLE ADDENDUMS. INTERMEDIATE BACKFILL, FINAL BACKFILL, AND ALL ROAD SECTIONS MUST BE CONSTRUCTED IN ACCORDANCE WITH THE GOVERNING JURISDICTION'S STANDARD CONSTRUCTION SPECIFICATIONS.
2. THE CONTRACTOR MUST NOTIFY THE APPROPRIATE INSPECTION OFFICE AT LEAST FIVE WORKING DAYS IN ADVANCE OF BEGINNING WORK:
 - a. FOR COLLECTOR LINES (GENERALLY SMALLER THAN 12-INCH DIAMETER)
 - i. CONTACT THE SACRAMENTO COUNTY CONSTRUCTION MANAGEMENT AND INSPECTION DIVISION AT 916-875-2700 FOR PROJECTS LOCATED WITHIN THE UNINCORPORATED COUNTY AND CITIES OF CITRUS HEIGHTS, RANCHO CORDOVA, AND ELK GROVE.
 - ii. CONTACT THE PUBLIC UTILITIES DEPARTMENT AT 916-808-6810 FOR PROJECTS LOCATED WITHIN THE CITY OF SACRAMENTO.
 - b. FOR PUMP STATIONS, FORCE MAINS, AND TRUNK LINES (GENERALLY 12-INCH DIAMETER AND LARGER)
 - i. CONTACT THE SACRAMENTO COUNTY CONSTRUCTION MANAGEMENT AND INSPECTION DIVISION AT 916-875-2700.
3. PLANS MUST BE RESUBMITTED FOR APPROVAL IF CONSTRUCTION OF SEWER FACILITIES HAS NOT STARTED WITHIN ONE YEAR FROM THE PLAN APPROVAL DATE.
4. ALL WORK MUST BE INSPECTED BY THE SACSEWER INSPECTOR BEFORE BACKFILLING THE PIPE ZONE.
5. DIMENSIONS SHOWN ON PLANS ARE TO THE CENTERLINE OF PIPES AND OR MANHOLES UNLESS OTHERWISE NOTED.
6. TYPE II OR TYPE III BEDDING AND BACKFILL IS REQUIRED UNLESS OTHERWISE NOTED.
7. MAXIMUM STANDARD LENGTH PIPE SECTIONS MUST BE USED EXCEPT WHERE OTHERWISE SPECIFIED ON THE PLANS OR STANDARD DRAWINGS.
8. GRAVITY LOWER LATERALS MUST BE CONSTRUCTED OF ABS SCHEDULE 40, HDPE DR 17, PVC C900 OR SDR 26, OR EXTRA STRENGTH VCP AND BEDDED AND CONSTRUCTED PER STANDARD DRAWINGS P-01 AND LL-01A, RESPECTIVELY. PLANS MUST SPECIFY THE PIPE MATERIAL.
9. CONSTRUCTION OF A CLEANOUT TO GRADE FOR ALL LOWER LATERALS IS REQUIRED PER STANDARD DRAWING LL-02.
10. ANY WATER ENTERING THE SEWER SYSTEM CONSTRUCTED UNDER THESE PLANS MUST NOT BE DISCHARGED TO THE EXISTING SEWER SYSTEM. APPROPRIATE WATERTIGHT PLUGS MUST BE INSTALLED AS NECESSARY. ALL WATER AND DEBRIS IN NEW SYSTEMS MUST BE REMOVED BEFORE FIELD ACCEPTANCE. CARE MUST BE EXERCISED IN PLACING PLUGS TO AVOID INTERRUPTING SERVICE CONNECTIONS. MECHANICAL PLUGS WITH BRICK AND MORTAR MUST BE USED. INFLATABLE PLUGS ARE NOT ALLOWED.
11. SACSEWER REQUIRES TELEVISION INSPECTION OF ALL CONSTRUCTED MAIN LINES IN ACCORDANCE WITH SECTION 331 OF THE STANDARDS. THE SACSEWER INSPECTOR MUST SIGN PLANS ON PROVIDED SIGNATURE BLOCK "OK TO SUBMIT FOR GRID NUMBERING" AFTER INSTALLATION OF ALL SEWER FACILITIES BEFORE OBTAINING GRID NUMBERS FOR TELEVISION INSPECTION.
12. FOR THE CURRENT LIST OF SACSEWER APPROVED TV CONTRACTORS GO TO https://www.sacsewer.com/sites/main/files/file-attachments/sasd_approved_tv_contractors_2019_list_-_new_assets.pdf?1604447584 OR CALL 916-876-PLAN (7526)
13. DEWATERING MUST BE PERFORMED AS NECESSARY TO PROVIDE A STABLE TRENCH BOTTOM FOR PLACEMENT OF SEWER FACILITIES. BEFORE THE CONTRACTOR PLACES MATERIALS IN THE TRENCH, THE BOTTOM OF THE TRENCH MUST BE CERTIFIED BY A GEOTECHNICAL ENGINEER VERIFYING THAT THE TRENCH MEETS THE REQUIREMENTS SPECIFIED IN THE GEOTECHNICAL REPORT. ADDITIONAL REQUIREMENTS FOR UNSTABLE CONDITIONS MUST BE AT THE WRITTEN DIRECTION OF THE PROJECT GEOTECHNICAL ENGINEER OF RECORD AND APPROVED BY SACSEWER. GEOTEXTILE FABRIC IS REQUIRED AS SHOWN AND DETAILED IN STANDARD DRAWING P-01.
14. AT LEAST 72 HOURS BEFORE STARTING CONSTRUCTION, THE CONTRACTOR MUST POTHOLE EXISTING CONNECTION POINTS AND CRITICAL UTILITY CROSSINGS IF THESE CONNECTION POINTS AND CRITICAL UTILITY CROSSINGS WERE NOT POTHOLED DURING DESIGN. NOTIFY SACSEWER INSPECTOR OF ANY CHANGES FROM THE APPROVED PLANS. CHANGES FROM THE APPROVED PLANS MUST BE SUBMITTED TO AND APPROVED BY SACSEWER AS A PLAN REVISION BEFORE CONSTRUCTION MAY START.